

Engineer in Chief cum  
Technical Advisor

Chief Engineer (South),  
Punjab Water Supply & Sewerage Board,  
Bathinda.

No. PWSSB-2018/Q.C.I. SS 01 Dated: 28/3/18

**Subject: - Inspection of ongoing works at Ferozpur town on dated 22-3-18  
(Er.J.S Bhattal & SDE, QC)**

During the visit of Quality Control team at Ferozpur on dated 22-03-2018 the following points have come to our notice:-

- (A) **Providing and Laying of Water Supply at Ferozpur.**
- (i) Various areas where water supply has already been laid was visited and noticed that the consolidation of earthwork is not proper and at some points dressing of earth is required to avoid any inconvenience to general public.
- (B) **Construction of 18 MLD STP at Ferozpur**
- (i) The Construction work was just started after many months. RCC connection of C-Tech basin to CCT was just started.
- (ii) The Engineer of the Agency was directed to push up the work, so that STP could be commissioned.

You are requested to report within 7 days after attending to the observations pointed above.

*10/3/18*  
*21/3/18*  
Executive Engineer (Q.C)  
For Engineer in Chief cum  
Technical Advisor